

Minutes Meeting September 8, 1997

Members present: Connie Ohman, Debbie Mielke, Chris Blair, Richard Nault, David Dempsey

ROCHEDIEU: RDA Install a nature walk and dock. A path of dirt and wood chips. There will also be a fence. Richard inspected. They initially wanted to make a driveway to the lake. There will need to be trees cut, nothing larger than 3' will be taken down. There needs to be some sort of retaining structure because the steps will wash out. Terrace it with landscaping ties. The dock will require a building permit. Chris Blair felt it would channel water directly to the lake. Connie suggested making a switch back at the bottom. They will need steps at the end.

Chris Blair wants more detail in the dock. There will be piers. Make the dock portable and take it out. Could use existing piers. All hand work no machinery N2.

Connie Ohman will get the video from Eric Montgomery.

HALSTEAD: RDA Beartown Mt. Septic system replacement. The area is flat. Steel tanks will be pumped and then removed. It is better than what is there now. The new tank will be polyethylene Determination N3

8:00 p.m. DOUGLAS ROY/REITTER NOI Represented by Marshall White This filing was for the septic and the water lines. Cautioned to imbed the silt fences better than during the well project.

They will be required to seed and mulch. Will hold the Order of Conditions until Board of Health approval has been obtained.

8:30 p.m. LYN SCHREIBER NOI Represented by Marshall White and Phil Timpane. Marshall White explained the project, site development of a single family dwelling, a portion of the construction of a driveway, site grading, construction of a water supply, well and construction of a septic tank and pump chamber. There will be a minimal removal of trees. There is an intermittent stream. They will install a line of silt fence.

WELLENKAMP: A Certificate of Completion will be issued to John Wellenkamp for his project on Beartown Mt. Rd. Richard Nault had inspected the project and reported that it had been completed as per the Order of Conditions.

LAKE GARFIELD: The Commission approved a full drawdown of Lake Garfield. Begin after Oct 1 and complete by October 15. Spring fill to begin in February.

TOWN REPORT: It is time to submit the report. It will cover the period July 1, 1996 to June 30, 1997.

Meeting adjourned 9:30 p.m.

